

**BUILDING ACCESSIBILITY FOR INDIVIDUALS WITH MOBILITY ISSUES OR PROBLEMS**

| <u>Academic Buildings/Classrooms</u>                             | <u>Automatic Entrance</u> | <u>Elevators</u> | <u>Accessible Restrooms</u> | <u>Notes</u>  |
|--|---------------------------|------------------|-----------------------------|---|
| All Resident Halls   | Yes                       | Yes              | Yes                         | GUILD MEMORIAL DOES NOT HAVE A PUSH BUTTON AT SOUTH MAIN ENTRANCE                         |
| Art Psychology Building  | Yes                       | Not Applicable   | No                          | ONLY ON WEST ENTRANCE   |
| Athletic Recreation Center (ARC)                                 | Yes                       | Yes              | No                          | RESTROOMS NEED PUSHBUTTONS. THERE IS NO ELEVATOR BUT THERE IS A CHAIR LIFT.               |
| Center for Diaconical Ministry                                   | No                        | Not Applicable   | No                          |   |
| Center for the Sciences  | Yes                       | Yes              | Yes                         |   |
| Chapel of the Resurrection                                       | Yes                       | No               | Yes                         | CAN BE COMBINED WITH HELGE CENTER WHICH HAS A RAMP TO ACCESS DIFFERENT LEVELS             |
| Christopher Center for Library and Information Resources (CCLIR) | Yes                       | Yes              | Yes                         |   |
| College of Arts and Sciences Building                            | Yes                       | Yes              | Yes                         |   |
| Confucius Institute  | No                        | No               | No                          | THIS IS A RESIDENTIAL HOUSE<br>2ND FLOOR IS NOT WHEELCHAIR/SCOOTER ACCESSIBLE             |
| Dickmeyer Hall   | Yes                       | No               | No                          |   |
| Facilities Management  | Yes                       | Not Applicable   | No                          | RESTROOM NEEDS PUSHBUTTON.  |
| Fitness Center   | Yes                       | Not Applicable   | No                          | 2ND FLOOR IS NOT WHEELCHAIR/SCOOTER ACCESSIBLE  |
| Gellersen/Fites Center   | Yes                       | No               | Yes                         |   |
| Harre Union  | Yes                       | Yes              | Yes                         |   |
| Health Center (Promenade East)                                   | Yes                       | Not Applicable   | Yes                         |   |
| Heidbrink Hall   | No                        | Not Applicable   | No                          | ENTRANCE IS MANUALLY ACCESSIBLE<br>INSTEAD OF ELEVATOR, THERE IS A RAMP.                  |
| Helge Center   | Yes                       | No               | No                          | RESTROOM NEEDS PUSHBUTTON   |
| Henrichs House   | No                        | No               | No                          | THIS IS A RESIDENTIAL HOUSE   |
| Heritage Hall  | Yes                       | Yes              | Yes                         |   |
| James S. Markiewicz Solar Energy Research Facility               | No                        | Not Applicable   | No                          | NEEDS PUSHBUTTON AT FRONT ENTRANCE  |
| Kade-Duesenberg German House and Cultural Center                 | Yes                       | Yes              | No                          | RESTROOM NEEDS PUSHBUTTON<br>NO ACCESSIBLE BUTTON BY ELEVATORS ON NORTH SIDE.<br>RESTROOM |
| Kallay-Christopher Hall  | No                        | Yes              | No                          | NEEDS PUSHBUTTON  |

BUILDING ACCESSIBILITY FOR INDIVIDUALS WITH MOBILITY ISSUES OR PROBLEMS

| <u>Academic Buildings/Classrooms</u>                | <u>Automatic Entrance</u> | <u>Elevators</u> | <u>Accessible Restrooms</u> | <u>Notes</u>  |
|---|---------------------------|------------------|-----------------------------|---|
| Kretzmann Hall                                      | No                        | No               | No                          |   |
| Kroencke Hall                                       | No                        | No               | No                          | NEED PUSH BUTTON TO ENTER TRACK PORTION.<br>NO PUSH BUTTON AT FOOTBALL ENTRANCE.<br>NEED LIFT TO ACCESS SOUTH PORTION OF<br>FOOTBALL AREA   |
| LeBien Hall   | No                        | No               | No                          |   |
| LeBien Hall Annex                                   | Yes                       | Yes              | No                          | RESTROOM NEEDS PUSHBUTTON.  |
| Linwood House                                       | No                        | No               | No                          |   |
| Loke Hall   | No                        | Not Applicable   | No                          | RESTROOM NEEDS PUSHBUTTON   |
| Meier Hall  | Yes                       | Not Applicable   | No                          |   |
| Mueller Hall  | Yes                       | No               | Yes                         | 104 (TIERED CLASSROOM) AND 03 & 04 (BASEMENT)<br>ARE NOT ACCESSIBLE   |
| Neils Science Center                                | Yes                       | Yes              | No                          | RESTROOM NEEDS PUSHBUTTON<br>RAMP ACCESS FROM KALLAY CHRISTOPHER.   |
| Schnabel Hall                                       | No                        | Yes              | No                          | RESTROOMS NEED PUSHBUTTON   |
| The Observatory                                     | No                        | Not Applicable   | No                          |   |
| University Mail Center                              | No                        | Not Applicable   | No                          | RESTROOMS NEED PUSHBUTTON AS WEEL AS<br>WIDER CLEARANCE TO ENTER.   |
| Urschel Hall  | Yes                       | No               | No                          | ROOM 2020 UNDER RENOVATION. PROJECT WILL<br>ADDRESS ADA TO INCLUDE A PUSHBUTTON AND<br>EXTERIOR ACCESS INTO THE ROOM.   |
| Valparaiso University Center for the Arts<br>(VUCA) | Yes                       | Yes              | Yes                         | DUESENBERG RECITAL HALL HAS NO PLACE FOR<br>WHEELCHAIR/SCOOTER<br>RESTROOM NEEDS PUSHBUTTON.<br>THE RAMP AT THE NORTHEAST ENTRANCE IS<br>BLOCKED AND NEEDS TO BE RENOVATED FOR CLEAR<br>ACCESS. |
| Valparaiso University Police Department             | Yes                       | No               | No                          |   |
| Wesemann Hall                                       | Yes                       | Yes              | No                          | RESTROOM NEEDS PUSHBUTTON   |