

BUILDING ACCESSIBILITY FOR INDIVIDUALS WITH MOBILITY ISSUES OR PROBLEMS

<u>Academic Buildings/Classrooms</u>	<u>Automatic Entrance</u>	<u>Elevators</u>	<u>Accessible Restrooms</u>	<u>Notes</u>
All Resident Halls	Yes	Yes	Yes	GUILD MEMORIAL DOES NOT HAVE A PUSH BUTTON AT SOUTH MAIN ENTRANCE
Art Psychology Building	Yes	Not Applicable	No	ONLY ON WEST ENTRANCE
Athletic Recreation Center (ARC)	Yes	Yes	No	RESTROOMS NEED PUSHBUTTONS. THERE IS NO ELEVATOR BUT THERE IS A CHAIR LIFT.
Center for Diaconical Ministry	No	Not Applicable	No	
Center for the Sciences	Yes	Yes	Yes	
Chapel of the Resurrection	Yes	No	Yes	CAN BE COMBINED WITH HELGE CENTER WHICH HAS A RAMP TO ACCESS DIFFERENT LEVELS
Christopher Center for Library and Information Resources (CCLIR)	Yes	Yes	Yes	
College of Arts and Sciences Building	Yes	Yes	Yes	
Confucius Institute	No	No	No	THIS IS A RESIDENTIAL HOUSE 2ND FLOOR IS NOT WHEELCHAIR/SCOOTER ACCESSIBLE
Dickmeyer Hall	Yes	No	No	
Facilities Management	Yes	Not Applicable	No	RESTROOM NEEDS PUSHBUTTON.
Fitness Center	Yes	Not Applicable	No	2ND FLOOR IS NOT WHEELCHAIR/SCOOTER ACCESSIBLE
Gellersen/Fites Center	Yes	No	Yes	
Harre Union	Yes	Yes	Yes	
Health Center (Promenade East)	Yes	Not Applicable	Yes	
Heidbrink Hall	No	Not Applicable	No	ENTRANCE IS MANUALLY ACCESSIBLE INSTEAD OF ELEVATOR, THERE IS A RAMP.
Helge Center	Yes	No	No	RESTROOM NEEDS PUSHBUTTON
Henrichs House	No	No	No	THIS IS A RESIDENTIAL HOUSE
Heritage Hall	Yes	Yes	Yes	
James S. Markiewicz Solar Energy Research Facility	No	Not Applicable	No	NEEDS PUSHBUTTON AT FRONT ENTRANCE
Kade-Duesenberg German House and Cultural Center	Yes	Yes	No	RESTROOM NEEDS PUSHBUTTON NO ACCESSIBLE BUTTON BY ELEVATORS ON NORTH SIDE. RESTROOM
Kallay-Christopher Hall	No	Yes	No	NEEDS PUSHBUTTON

BUILDING ACCESSIBILITY FOR INDIVIDUALS WITH MOBILITY ISSUES OR PROBLEMS

<u>Academic Buildings/Classrooms</u>	<u>Automatic Entrance</u>	<u>Elevators</u>	<u>Accessible Restrooms</u>	<u>Notes</u>
Kretzmann Hall	No	No	No	
Kroencke Hall	No	No	No	NEED PUSH BUTTON TO ENTER TRACK PORTION. NO PUSH BUTTON AT FOOTBALL ENTRANCE. NEED LIFT TO ACCESS SOUTH PORTION OF FOOTBALL AREA
LeBien Hall	No	No	No	
LeBien Hall Annex	Yes	Yes	No	RESTROOM NEEDS PUSHBUTTON.
Linwood House	No	No	No	
Loke Hall	Yes	Not Applicable	No	RESTROOM NEEDS PUSHBUTTON
Meier Hall	Yes	Not Applicable	No	
Mueller Hall	Yes	No	Yes	104 (TIERED CLASSROOM) AND 03 & 04 (BASEMENT) ARE NOT ACCESSIBLE
Neils Science Center	Yes	Yes	No	RESTROOM NEEDS PUSHBUTTON
Schnabel Hall	No	Yes	No	RAMP ACCESS FROM KALLAY CHRISTOPHER. RESTROOMS NEED PUSHBUTTON
The Observatory	No	Not Applicable	No	
Urschel Hall	Yes	No	No	ROOM 2020 UNDER RENOVATION. PROJECT WILL ADDRESS ADA TO INCLUDE A PUSHBUTTON AND EXTERIOR ACCESS INTO THE ROOM.
Valparaiso University Center for the Arts (VUCA)	Yes	Yes	Yes	DUESENBERG RECITAL HALL HAS NO PLACE FOR WHEELCHAIR/SCOOTER
Valparaiso University Police Department	Yes	No	No	RESTROOM NEEDS PUSHBUTTON. THE RAMP AT THE NORTHEAST ENTRANCE IS BLOCKED AND NEEDS TO BE RENOVATED FOR CLEAR ACCESS.
Wesemann Hall	Yes	Yes	No	RESTROOM NEEDS PUSHBUTTON